

Comhairle Contae Mhaigh Eo

Appendix 1

Boil Water Notices

GWS NAME	Location (Municipal District)	Commencement Date	Water Quality Failure	Proposed Action
Sraheens GWS	Foxford (Ballina Municipal District)	12/11/2015	No chlorine in Network	Chlorine levels raised in Plant, negotiations ongoing with DBO operator to take over rising mains and install chlorine boosting.
Knockinakell GWS	Claremorris (Claremorris Municipal District)	11/12/2015	16 Coliforms 1E.coli	Following site Audit HSE sampled and recommended BWN as the GWS has 0 treatment.
Cornboy GWS	Erris (West Mayo Municipal District)	25/08/2016	176 Coliforms	HSE Sampled scheme, twice, both times failed and recommended BWN. Scheme due to scour and disinfect.
Robeen GWS	Claremorris (Claremorris Municipal District)	03/10/2016	1 cryptosporidium oocysts	Further investigation into improvement in source.
Johnstown/ Lavallyroe GWS	Ballyhaunis (Claremorris Municipal District)	08/11/2018	41 Coliforms 19 E.coli	HSE Sampled well, wq failed and BWN was recommended.
Rosspport GWS	Erris (West Mayo Municipal District)	08/11/2018	201 Coliforms 83 E.coli	HSE Sampled well, wq failed and BWN was recommended.
Errew/Killeen/ Castlehill GWS	Crossmolina (Ballina Municipal District)	9/10/2019	21 Coliforms 8 E.coli	Water Quality Failure, BWN was recommended
Barnacarroll	Claremorris Municipal District	20/08/2020	Coliforms & E. coli	Water Quality Failure. BWN was recommended